

Report Number B 05/02/0698 from 28.02.2005

Inspection certificate


Corrugated pipes

Test basis:	In support to DVGW code of practice GW 354 (edition September 2002)
Company/ Client:	Tucai Sociedad Anonima C/. Llobateras, 10 - 12 ES-08210 Barbera del Valles (Barcelona)
Reason of testing:	Confirmation for use in drinking water systems
Kind of product:	Corrugated pipes made of stainless steel for gas and drinking water installation systems
Model:	RIVER INOX...
Dimensions:	DN 12, DN 16
Gases:	not for gas installation
Water:	Drinking water systems according DIN 1988, MOP 10 bar
Connections:	threads G 1/2" and G 3/4" according ISO 228-1



Registered parts:

product	model/type	registration number	company
O-rings seal	TIMO / 70		Tecnogamma
Fiber seal	GASFALIT	NG-5123AP1134	Willbrandt

The requirements of the named test basis are achieved.



Brödner
Head of Laboratory

Aßmann
test engineer